



DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Samples collected from "Holy Innocents Public School" Plot no. PS/09, C – Block, Vikaspuri, New Delhi - 110018 Vide Challan No. 349 Dated : - 02.11.2023.

S1:- DJB Supply

S2 :- Drinking Point water cooler R. O. water

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
<b>PHYSICAL EXAMINATION</b>						
1.	Date of collection	-----	--	--	10.11.2023	10.11.2023
2.	Date of Analysis	-----	--	--	11.11.2023	11.11.2023
3.	Colour	Hazen	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	2.6	1.0
6.	PH value	-----	6.5	8.5	7.42	6.8
7.	Electrical Conductivity	µmho	--	--	303.8	196.2
8.	Total dissolved solids	mg/l	500	2000	197.47	127.4
<b>CHEMICAL EXAMINATION</b>						
9.	Phenolphthalein Alkalinity	mg/l	--	--	Nil	Nil
10.	Total Alkalinity	mg/l	200	600	98	40
11.	Total Hardness	mg/l	200	600	128	52
12.	Calcium Hardness	mg/l	--	--	86	38
13.	Magnesium Hardness	mg/l	--	--	42	14
14.	Calcium as Ca	mg/l	75	200	34.4	15.2
15.	Magnesium as Mg	mg/l	30	100	10.08	3.36
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO <sub>3</sub>	mg/l	45	N.R.	3.0	1.2
19.	Sulphate	mg/l	200	400	34	14
20.	Chloride	mg/l	250	1000	14	70
21.	Dissolved Iron	mg/l	0.3	N.R.	0.06	0.02
22.	Fluoride	mg/l	1	1.5	0.22	0.04
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.25	NIL
<b>BACTERIOLOGICAL EXAMINATION</b>						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS : As per tested parameters sample - S1 & S2 can be use for drinking purpose.

*Shashi Kant*  
Principal  
Holy Innocents Public School  
(Senior Secondary) Plot No. PS/09,  
C-Block, Vikas Puri, N. Delhi

*Lalini Meen*  
Chemist

*Chairman*  
Holy Innocents Public School  
Vikas Puri, New Delhi

*S. Pandey*  
ACWA  
Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works Nangloi, Delhi-41



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, WEST ZONE  
DR. SAHIB SING VERMA NIGAM BHAWAN  
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D-3727

Dated: 13/2/24

**HEALTH CERTIFICATE**

1. Name of the School Holy Innocents Public School
2. School address Plot No-PS/09,C-Block Vikaspuri New Delhi-110018
3. No of shifts 01 (Morning)
4. No of students:- Boys 937 Girls 593 Total 1530
5. No of staff: - Gents 03 Ladies 39 Total 42

**Accommodation provide for classroom as under:-**

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. Not required
- Drinking water is wholesome/ not wholesome Wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue

Vice Principal/ HOS  
Holy Innocents Public School  
(Senior Secondary) Plot No. PS/09  
C-Block, Vikas Puri, N. Delhi

Chairman  
Holy Innocents Public School  
Vikas Puri, New Delhi

Dy. Health Officer  
West Zone  
Dr. V. N. Singh  
DHO (West Zone)